

Table 5A

Statement of Electrical Accident (2021-22)				
I	Fatal Electrical Accident	TOTAL		Total
		H	A	F
1	Total Fatal Accidents	236	88	324
2	Electrical Accident occurred to contract Staff	13	0	13
3	Electrical Accident occurred to Board Staff	9	0	9
4	Electrical Accident occurred to public	214	7	221
5	Electrical Accident occurred while using Iron rod/ladder	36	0	36
6	Electrical Accident occurred from cable TV	1	0	1
7	Electrical accident occurred due to snapping of conductor	14	51	65
8	Total no. of person met with accident in Consumer Premises	133	12	145
9	Total no. of person met with accident in KSEB installation	100	76	176
10	Total no. of person met with accident in Industrial Premises	3	0	3
11	Total no of Electrical Accidents occurred from unauthorised fencing	7	2	9
II	Non-Fatal Electrical Accident	TOTAL		Total
		H	A	NF
1	Total Non-Fatal Accidents	152	0	152
2	Electrical Accident occurred to contract Staff	27	0	27
3	Electrical Accident occurred to Board Staff	18	0	18
4	Electrical Accident occurred to public	105	0	105
5	Electrical Accident occurred while using Iron rod/ladder	27	0	27
6	Electrical Accident occurred from cable TV	1	0	1
7	Electrical accident occurred due to snapping of conductor	14	0	14
8	Total no. of Accident in Consumer Premises	26	0	26
9	Total no. of Accident in KSEB installation	120	0	120
10	Total no. of Accident in Industrial Premises	6	0	6
11	Total no of Electrical Accidents occurred from unauthorised fencing	3	0	3

H- Human

A-Animal